

# Venting Do Not's

**Do Not** locate the terminal less than 7 feet above public walkways. This applies to steps and stairwells as well.

**Do Not** locate the termination where condensate may present a problem such as flower beds, patios etc.

**Do Not** locate within 4 feet of gas or electric meter or gas regulator.

**Do Not** locate the vent terminal within 4 feet of an adjacent building.

**Do Not** locate within 12 inches above an operable window.

**Do Not** locate vent less than 4 feet below or beside any door, window or gravity air inlet into any building.

**Do Not** locate within 3 feet of any inside corner of a building structure.

*Also when possible vent termination should not be subject to prevailing winds and should terminate at least 12 inches above the expected snow depth. Consideration should be given to past unusual snow falls.*